
Technical data sheet

Trunking unit for GES4, height 40-140 mm

Item number: 7424122





Ready-to-mount screed-flush trunking unit for cable routing, consisting of three system covers, two side profiles with attached flexible side wall made of metallic mesh, floor covering contact profiles with H = 3 mm. For dry interior rooms with dry-care floors. Also suitable for wet-care floors with appropriate system accessories. The scope of delivery contains six height-adjustable fastening brackets, six screed ties and three lid butt seals for nominal trunking widths 200, 300 and 400 or six lid butt supports for trunking widths 500 and 600. The essential levelling units (please observe adjustment height) for the lid butt supports 400, 500 and 600 are not contained in the scope of supply, please order separately. On delivery, the trunking lids are screwed on.

With screw-on device installation lids, each with an installation opening for a square installation unit nominal size 4.



St


Steel

FS

Strip galvanized

Master data

7424122
OKA-G40040140D4
Flushfloor trunking unit
for service unit GES7
OBO
2400x400x140
Steel
Strip galvanized
DIN EN 10346
2.4
Metre
1453.3 kg
kg/100 m



Length	2,400 mm
Width	400 mm

Technical data sheet

Trunking unit for GES4, height 40-140 mm





Technical data		
	Mounting opening cover	yes
	Covers	3
	Number of planned flush-mount units	3
	Mounting system fastening type	Floor
	Floor plate	no
	Cover fastening, locking	no
	Seal installation option	yes
	Installation opening for on-floor tank	no
	Decouplable	yes
	Suitable for expansion joint	no
	Mesh wall	yes
	Trunking height, max.	140 mm
	Duct height, min.	40 mm
	Cover material thickness	4
	Minimum screed height	40
	With connection opening	yes
	With equipotential bonding	no
	With separating retainer	no
	With overhang	yes
	Mounting opening	For service outlet
	Mounting opening	Square
	Nominal size for device installation units	4
	Height-adjustment range, max.	140 mm
	Height-adjustment range, min.	40 mm
	Removable cover	yes